

B.1. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

Discharge to Unnamed Tributary of Franks Creek - Outfall #001 (30.983325°, -83.377761°):

- a. The discharge from the water pollution control plant shall be limited and monitored by the permittee starting on the effective date of the permit and continuing for 54 months as follows:

Parameters	Discharge limitations in mg/L (lbs/day) unless otherwise specified		Monitoring Requirements		
	Monthly Average	Weekly Average	Measurement Frequency	Sample Type	Sample Location
Flow (MGD) ⁽¹⁾	--	--	Seven Days/Week	Continuous Recording	Effluent
January - April	0.275	0.344			
May – October	0.0	0.0			
November - December	0.275	0.344			
Five-Day Biochemical Oxygen Demand ⁽²⁾	20 (46)	30 (57)	Two Days/Week	Composite	Influent & Effluent
Total Suspended Solids ⁽²⁾	30 (69)	45 (86)	Two Days/Week	Composite	Influent & Effluent
Ammonia, as N ⁽³⁾	10.0 (23)	15.0 (29)	Two Days/Week	Composite	Influent & Effluent
<i>Escherichia Coli</i> (CFU/100mL)	126	410	One Day/Week	Grab	Effluent

- (1) During the winter months (November -April), the permittee must maximize the use of the land treatment system and discharge to the unnamed tributary to Franks Creek only when the sprayfields cannot absorb any additional water.
- (2) Numeric limits only apply to the effluent.
- (3) Refer to Part I.C.8 AMMONIA, TOTAL PHOSPHORUS, AND TOTAL NITROGEN COMPLIANCE SCHEDULE

(Effluent limitations continued on the next page)