DL19-004 Attachment 3 - Homerville NOI and NRC reports.pdf

Complete the following if any Pipe, Weld, or Joint Failure sub-cause is selected.	
24. Additional Factors (select all that apply):	·
- Dent	
- Gouge	
- Pipe Bend	
- Arc Burn	
- Crack	
- Lack of Fusion	
- Lamination	
- Buckle	
- Wrinkle	
- Misalignment	
- Burnt Steel	
- Other	
- If Other, Specify:	
25. Was the Incident a result of:	
- Construction defect	
Specify:	
- Material defect	
Specify:	
- If Other, Specify:	
- Design defect - Previous damage	
Previous damage Resource test been conducted since original construction	
at the point of the Incident?	
- If Yes:	
Most recent year tested:	
Test pressure:	
G6 - Equipment Failure - only one sub-cause can be selected from the shaded left-hand column	
Equipment Failure – Sub-Cause:	
- If Malfunction of Control/Relief Equipment:	
Specify:	
- Control Valve	
- Instrumentation	
- SCADA	
- Communications	
- Block Valve	
- Check Valve	
- Relief Valve	
- Power Failure	
- Stopple/Control Fitting	
- Pressure Regulator	
- Other	
- If Other, Specify:	
- If Threaded Connection Failure:	
2. Specify:	
- If Other, Specify:	
- If Non-threaded Connection Failure:	
3. Specify:	
- If Other, Specify:	
- If Valve:	
4. Specify:	
- If Other, Specify:	
4a. Valve type:	
4b. Manufactured by:	
4c. Year manufactured:	
- If Other Equipment Failure:	
5. Describe:	
G7 - Incorrect Operation - only one sub-cause can be selected from the shaded left-hand column	
Incorrect Operation Sub-Cause:	
- If Other Incorrect Operation:	
1. Describe:	
ii. Doddinot.	

Form PHMSA F 7100.1