3.0 EMERGENCY PLANS AND PROCEDURES

This section contains plans and procedures that can be implemented in the event of a malevolent act or natural hazard that threatens your utility's ability to deliver safe drinking water.

3.1 Core Response Procedures

Core procedures are the "building blocks" for incident specific response procedures, as they are typically implemented across a broad variety of incidents (e.g., hurricane, earthquake, flood). List all your core procedures here.

| WPCP Access | | |
|-------------------------|---|--|
| Item | Description | |
| Debris clearing | Utilities Department Central Lines Division has available backhoe tractors and dump trucks. Public Works Department has debris clearing equipment and would be contacted if needed. (Listed in external contact list) | |
| Alternate routes to WTP | Main route: Wetherington Lane off of Highway 84 | |
| Identification badges | All WPCP staff and employees of Utilities Department have a photo ID badge. | |
| Plant entry gate | Access into WPCP is controlled by entry gate. Gate is unlocked and opened at 7:00 am. Closed and locked at 5:00 pm | |

| WWTP Physical Security | | |
|---------------------------|---|--|
| Item | Description | |
| Access control procedures | The WPCP has fencing at 72"and include rolled barbed wire headers. Gates are kept operational and locked with single locks only with only authorized system employees having keys. Access into WPCP is controlled by entry gate. WPCP have security lights. Law enforcement notified of any suspicious activity. Operations Building front door locked. | |
| Restricted areas | The WPCP, and right of way to outfall are considered restricted areas. Only authorized employees of the Utilities Department may enter restricted areas unaccompanied. All other people are required to be accompanied by an authorized employee of the WPCP at all times while in restricted areas. All restricted areas shall be visibly marked "Restricted Area / Authorized Personnel Only" and shall be kept locked and secure at all times when an employee is not onsite. Other security measures shall also be followed to prevent the unauthorized use, theft, or damage to water system property. | |
| Evidence protection | If criminal activity is suspected, secure the site, and protect any evidence. Contact local | |
| measures | and state authorities. | |