

UTILITIES DEPARTMENT

PH: 229-259-3592

FAX: 229-241-8285

Emergency: 229-434-4132

Director of Utilities

[Jason Barnes](#)



MAJOR SPILL REPORT TO EPD Sugar Creek Broken Line.

TIME/DATE OF MAJOR SPILL: 1/6/2025-1/10/25

START/STOP TIME: 1/6/25 @ 01130 -1/10/25 @13:30

REPORT SUBMITTED: 1/10/2025.

LOCATION OF MAJOR SPILL (GPS location): 30.85535924232464, -83.31550739683205

CAUSE OF MAJOR SPILL: Pipe separation due to erosion.

ESTIMATED VOLUME DISCHARGED: 15,000 gallons.

RECEIVING WATERS: Withlacoochee River via Sugar Creek

SERVICE BASIN AFFECTED: Suwanee RB

WWTP SERVICE AREA NPDES PERMIT: Withlacoochee GA0033235

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:

Sign posted and area under repair. Line is on bypass.

SPILL STATUS: Stop

SIGNS POSTED: Yes.

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL:

Pipe being bypassed. Reviewing options to move line to another location and abandon current older system.

DATE STREAM MONITORING INITIATED: 1/10/2025

DATE MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: 1/8/2025

REPORT SUBMITTED BY: Joseph Gangler