

Summary Page

Name of Facility Moody Air Force Base

NPDES Permit No. GA0020001

This permit is a modification of an NPDES permit for United States Department of Air Force – Moody Air Force Base. The facility discharges an average 0.72 MGD of sanitary wastewater, groundwater infiltration, storm water runoff, potable water treatment, wastewater from vehicle maintenance, wastewater from vehicle and aircraft wash racks, and groundwater treatment system wastewater. This facility discharges to Beatty Branch in the Suwannee River Basin. The permit expires on August 31, 2022.

The permit was placed on public notice from March 29, 2019 to May 1, 2019.

Please Note The Following Changes to the Proposed NPDES Permit From The Existing Permit

Part I.A.1. – Effluent Limitations and Monitoring Requirements

- Modified the ammonia daily average and daily maximum limits from 0.24/0.36 mg/L for May – October and 0.41/0.62 mg/L for November-April to 1.79/2.69 mg/L for the months of October – December, 2.85/4.28 mg/L for the months of January – March, 1.4/2.1 mg/L for the months of April – June, and 1.22/1.83 mg/L for the months of July – September per EPD’s *Strategy for Addressing Ammonia Toxicity* (July 2017).
- Removed ammonia recalculation compliance schedule.
- Modified pH limit to 6.0 – 7.0 s.u. daily minimum and daily maximum, respectively based on the ammonia toxicity alternative analysis (fact sheet appendix A).

Standard Conditions & Boilerplate Modifications

The permit boilerplate includes modified language or added language consistent with other NPDES permits.

Determinations and Public Comments

- Final issued permit did not change from the draft permit placed on public notice.
- Final permit includes changes from the draft permit placed on public notice. See attached permit addendum and/or permit fact sheet addendum.
- Public comments were received during public notice period.
- Public hearing was held.