

**B.1. TREATMENT REQUIREMENTS, LIMITATIONS AND MONITORING**

- a. Influent shall refer to the influent to the treatment facility and effluent shall refer to the discharge from the treatment pond to the storage pond. The discharge shall be limited and monitored as follows:

Parameter (units)	Discharge Limitations Monthly (Weekly) average, unless otherwise stated	Monitoring Requirements		
		Measurement Frequency	Sample Type	Sample Location
Flow (MGD)	1.3 (1.62)	Seven Days/Week	Continuous	Influent
Five-Day Biochemical Oxygen Demand (mg/L)	50	One Day/Week	Grab	Influent & Effluent
Total Suspended Solids (mg/L)	90	One Day/Week	Grab	Influent & Effluent
pH (standard units), minimum & maximum	Report	One Day/Week	Grab	Effluent