

b. SAMPLING PERIOD

1. Unless otherwise specified in this permit, quarterly samples shall be taken during the periods January-March, April-June, July-September, and October-December.
2. Unless otherwise specified in this permit, semiannual samples shall be taken during the periods January-June and July-December.
3. Unless otherwise specified in this permit, annual samples shall be taken during the period of January-December.

c. MONITORING AND ANALYZING PROCEDURES

1. All analytical methods, sample containers, sample preservation techniques, and sample holding times must be consistent with the techniques and methods listed in 40 CFR Part 136, as amended. The analytical method used shall be sufficiently sensitive. Parameters must be analyzed to the detection limits. The parameters will be reported as "not detected" or "ND" when they are below the detection limit and will then be considered in compliance with the effluent limit. The detection limit will also be reported on the DMR or OMR in accordance with Part I.A.3 of this permit.
2. In accordance with 40 CFR Part 136, as amended and as applicable, all analyses shall be made in accordance with the latest edition of Standard Methods for the Examination of Water and Wastewater, Methods for Chemical Analysis of Water and Wastes, or other approved methods.

d. ADDITIONAL MONITORING BY PERMITTEE

If the permittee monitors required parameters at the locations designated in Part I.B of this permit more frequently than required, the permittee shall analyze all samples using approved analytical methods. The results of this additional monitoring shall be included in calculating and reporting the values on the DMR and OMR. The permittee shall indicate the monitoring frequency on the report. EPD may require in writing more frequent monitoring, or monitoring of other pollutants not specified in this permit.