

e. FLOW MONITORING

1. Measurements shall be conducted using the flow measuring device(s) in accordance with the approved design of the facility. If secondary flow measurement device(s) are installed, calibration shall be maintained to $\pm 10\%$ of the actual flow. Flow shall be measured manually to check the flow meter calibration at a frequency of once a month. If secondary flow instruments are in use and malfunction or fail to maintain calibration as required, the flow shall be computed from manual measurements or by other method(s) approved by EPD until such time as the secondary flow instrument is repaired.
2. For facilities which utilize approved alternate technologies for measuring flow, the flow measurement device must be calibrated semi-annually by qualified personnel.
3. Records of the calibration checks shall be maintained on site in accordance with the requirements of Part. I.A.2.f. of the permit.

f. RECORDING OF RESULTS

For each measurement of sample taken pursuant to the requirements of this permit, the permittee shall record the following information:

1. The exact place, date, and time of sampling, and the person(s) collecting the samples;
2. The dates and times the analyses were performed;
3. The person(s) who performed the analyses;
4. The analytical procedures or methods used; and
5. The results of all required analyses.