

B.1. TREATMENT REQUIREMENTS, LIMITATIONS AND MONITORING

The discharge shall be limited and monitored as follows:

Parameter (units)	Discharge Limitations Monthly (Weekly) average, unless otherwise stated	Monitoring Requirements		
		Measurement Frequency	Sample Type	Sample Location ⁽¹⁾
Flow (MGD)	1.3 (1.62)	Seven Days/Week	Continuous	Influent
Five-Day Biochemical Oxygen Demand (mg/L) ⁽²⁾	50	One Day/Week	Grab	Influent & Effluent
Total Suspended Solids (mg/L) ⁽²⁾	90	One Day/Week	Grab	Influent & Effluent
pH (standard units), Daily Minimum & Daily Maximum	6.0 – 9.0	One Day/Week	Grab	Effluent

⁽¹⁾ Influent shall refer to the influent to the treatment facility
Effluent shall refer to the discharge from the treatment pond to the storage pond.

⁽²⁾ Numerical limits only apply to effluent.