

TBELs aim to prevent pollution by requiring a minimum level of effluent quality that is attainable using demonstrated technologies for reducing discharges of pollutants or pollution into the waters of the State. TBELs are developed independently of the potential impact of a discharge on the receiving water, which is addressed through water quality standards and WQBELs. The NPDES regulations at 40 C.F.R. §125.3(a) require NPDES permit writers to develop technology-based treatment requirements, consistent with CWA section 301(b), that represent the minimum level of control that must be imposed in a permit. The regulation also requires permit writers to include in permits additional or more stringent effluent limitations and conditions, including those necessary to protect water quality.

40 CFR Part §122.44(a)(1) requires that NPDES permits include applicable technology-based limitations and standards, while regulations at § 125.3(a)(1) state that TBELs for publicly owned treatment works must be based on secondary treatment standards and the “equivalent to secondary treatment standards” (40 CFR Part 133). The regulation applies to all POTWs and identifies the technology-based performance standards achievable based on secondary treatment for five-day biochemical oxygen demand (BOD₅), total suspended solids (TSS), and pH.

The table below shows the secondary treatment standards:

Parameter	Secondary Treatment Standards	
	30-day Average	7-day Average
BOD ₅	30 mg/L	45 mg/L
TSS	30 mg/L	45 mg/L
TSS & BOD ₅ removal (concentration)	≥ 85%	--
pH (Daily Minimum – Daily Maximum)	6.0-9.0 S.U.	

4.2 Reasonable Potential Analysis (RPA)

EPA regulations at 40 C.F.R. §122.44(d)(1)(i) state, “Limitations must control all pollutants or pollutant parameters (either conventional, nonconventional, or toxic pollutants) which the Director determines are or may be discharged at a level that will *cause*, have the *reasonable potential to cause*, or *contribute* to an excursion above any [s]tate water quality standard, including [s]tate narrative criteria for water quality.”

EPA regulations at 40 C.F.R. §122.44(d)(1)(ii) require States to develop procedures for determining whether a discharge causes, has the reasonable potential to cause, or contributes to an instream excursion above a narrative or numeric criterion within a state water. If such reasonable potential is determined to exist, the NPDES permit must contain pollutant effluent limits and/or effluent limits for whole effluent toxicity. Georgia has reasonable potential procedures, based upon the specific category of pollutants and/or specific pollutant of concern. Chemical specific and biomonitoring data and other pertinent information in EPD’s files will be considered in accordance with the review procedures specified in the GA Rules and Regulations for Water Quality Control, Chapter 391-3-6 in the evaluation of a permit application and in the evaluation of the reasonable potential for a discharge to cause an exceedance in the numeric or narrative criteria.

The term “pollutant” is defined in CWA section 502(6) and 40 C.F.R. §122.2. Pollutants are grouped into three categories under the NPDES program: conventional, toxic, and