

B.1. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

Discharge to Cat Creek - Outfall #001 (31.068727°, -83.207118°):

- a. The discharge from the Ray City water pollution control plant shall be limited and monitored by the permittee as specified below starting on the effective date of the permit and continuing for 36 months:

Parameters	Discharge limitations in mg/L (lbs/day) unless otherwise specified		Monitoring Requirements		
	Monthly Average	Weekly Average	Measurement Frequency	Sample Type	Sample Location
Flow (MGD)	0.1	0.125	One Days/Week	Instantaneous	Effluent
Five-Day Biochemical Oxygen Demand ⁽¹⁾⁽²⁾	30 (25.0)	45 (31.3)	One Day/Week	Grab	Influent & Effluent
Total Suspended Solids ^{(1) (2)}	90.0 (75.1)	120.0 (93.8)	One Day/Week	Grab	Influent & Effluent
Fecal Coliform Bacteria (#/100 mL)	200	400	Two Days/Month	Grab	Effluent

⁽¹⁾ Numeric limits only apply to the effluent.

⁽²⁾ Refer to Part I.C.8. TOTAL SUSPENDED SOLIDS, FIVE-DAY BIOCHEMICAL OXYGEN DEMAND, AMMONIA, DISSOLVED OXYGEN, TOTAL NITROGEN, AND TOTAL PHOSPHORUS COMPLIANCE SCHEDULE

(Effluent limitations continued on the next page)