

B.2. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

(CONTINUED)

Discharge to Cat Creek - Outfall #001 (31.068727°, -83.207118°):

Parameters	Discharge limitations in mg/L unless otherwise specified	Monitoring Requirements		
		Measurement Frequency	Sample Type	Sample Location
Five-Day Biochemical Oxygen Demand Removal, Minimum (%) <sup>(1)</sup>	85	See Below	See Below	See Below
Total Suspended Solids Removal, Minimum (%)	85	See Below	See Below	See Below
pH, Daily Minimum – Daily Maximum (Standard Unit)	6.0 – 8.5	One Day/Week	Grab	Effluent
Total Residual Chlorine, Daily Maximum	0.02	One Day/Week	Grab	Effluent
Dissolved Oxygen, Daily Minimum <sup>(2)</sup>	6.0	One Day/Week	Grab	Effluent
Orthophosphate, as P <sup>(3)(5)</sup>	Report	One Day/Month	Grab	Effluent
Organic Nitrogen, as N <sup>(4)(5)</sup>	Report	One Day/Month	Grab	Effluent
Nitrate-Nitrite, as N <sup>(4)(5)</sup>	Report	One Day/Month	Grab	Effluent
Total Kjeldahl Nitrogen, as N <sup>(4)(5)</sup>	Report	One Day/Month	Grab	Effluent

<sup>(1)</sup> Percent removal shall be calculated from monthly average influent and effluent concentrations. Influent and effluent samples shall be collected at approximately the same time.

<sup>(2)</sup> Refer to Part I.C.8. TOTAL SUSPENDED SOLIDS, FIVE-DAY BIOCHEMICAL OXYGEN, DEMAND, AMMONIA, DISSOLVED OXYGEN, TOTAL NITROGEN, AND TOTAL PHOSPHORUS COMPLIANCE SCHEDULE

<sup>(3)</sup> Total phosphorus and orthophosphate must be analyzed from the same sample.

<sup>(4)</sup> Ammonia, organic nitrogen, nitrate-nitrite, total Kjeldahl nitrogen (TKN), and total nitrogen must be analyzed or calculated from the same sample. Organic nitrogen, as N = TKN – ammonia, as N. Total nitrogen is the sum of all nitrogen and calculated as follows: TN = TKN + nitrite + nitrate.

<sup>(5)</sup> Refer to Part I.C.9 COMPREHENSIVE NUTRIENT OPTIMIZATION PLAN.