

5.     OTHER NONCOMPLIANCE

The permittee must report all instances of noncompliance not reported under other specific reporting requirements, at the time monitoring reports are submitted. The reports shall contain the information required under conditions of twenty-four hour reporting.

6.     OPERATOR CERTIFICATION REQUIREMENTS

The person responsible for the daily operation of the facility must be a Class I Certified Operator in compliance with the Georgia State Board of Examiners for Certification of Water and Wastewater Plant Operators and Laboratory Analysts Act, as amended, and as specified by Subparagraph 391-3-6-.12 of the Rules and Regulations for Water Quality Control. All other operators must have the minimum certification required by this Act.

7.     LABORATORY ANALYST CERTIFICATION REQUIREMENTS

Laboratory Analysts must be certified in compliance with the Georgia State Board of Examiners for Certification of Water and Wastewater Treatment Plant Operators and Laboratory Analysts Act, as amended.

8.     BYPASSING

Any diversion of wastewater from or bypassing of wastewater around the permitted treatment works is prohibited, except if:

- a.     Bypassing is unavoidable to prevent loss of life, personal injury, or severe property damage;
- b.     There are no feasible alternatives to bypassing; and
- c.     The permittee notifies the EPD at least 10 days before the date of the bypass.

Feasible alternatives to bypassing include use of auxiliary treatment facilities and retention of untreated waste. The permittee must take all possible measures to prevent bypassing during routine preventative maintenance by installing adequate back-up equipment.

The permittee shall operate the facility and the sewer system to minimize discharge of pollutants from combined sewer overflows or bypasses and may be required by the EPD to submit a plan and schedule to reduce bypasses, overflows, and infiltration.

Any unplanned bypass must be reported following the requirements for noncompliance notification specified in II.A.3. The permittee may be liable for any water quality violations that occur as a result of bypassing the facility.