

- c. The pathogen density requirements and specific criteria listed in Chapter 391-3-6-.17(7) of the State Rules shall be monitored at the frequency listed in Part IV.A.5 of this permit.
  - d. The vector attraction reduction requirements and specific criteria, referenced in the approved SMP, listed in Chapter 391-3-6-.17(8)(a) through (8)(h) of the State Rules shall be monitored at the frequency listed in Part IV.A.5 of this permit.
5. The permittee will monitor the sewage sludge as required in Chapter 391-3-6.17(11)(a) of the State Rules at the below frequencies:

Amount of Sludge <sup>(1)</sup>	Frequency
0-300 dry tons/year	Once/year
300-1,600 dry tons/year	Once/quarter
1,600-16,000 dry tons/year	One/Two months
>16,000 dry tons/year	Once/Month

<sup>(1)</sup> The amount of sewage sludge refers to either the amount of bulk sewage sludge (dry weight) applied to the land, or the amount of sewage sludge (dry weight) received by a preparer that sells or otherwise distributes sewage sludge in a bag or other container for application to the land.

6. In accordance with Chapter 391-3-6-.17(12) of the State Rules, sewage sludge samples shall be analyzed using EPA approved methods contained in 40 CFR Part 503.8.
7. A proposed addition or removal of land application site(s) will be subject to EPD's review and approval process as outlined in the *Guidelines for Land Application of Sewage Sludge (Biosolids) at Agronomic Rates*, June 2006 as amended and in accordance with the State Rules. Upon approval of the SMP or an amendment of a SMP and the corresponding modification of the permit by the Director, the permittee may start land applying treated sewage sludge on the proposed sites.