

B.1. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

The discharge(s) from the water pollution control plant shall be limited and monitored by the permittee as specified below beginning on the effective date of the permit and continuing until construction of the 5.7 MGD facility is completed and EPD provides written authorization to commence operation under the B.2. (5.7 MGD) effluent limitations:

Parameters	Discharge limitations in mg/L (kg/day) unless otherwise specified		Monitoring Requirements		
	Monthly Average	Weekly Average	Measurement Frequency	Sample Type	Sample Location
Flow (MGD)	3.22	4.03	Seven Days/Week	Continuous Recording	Effluent
Biochemical Oxygen Demand, 5-day	10 (122)	15 (153)	Three Days/Week	Composite	Influent & Effluent
Total Suspended Solids	30 (366)	45 (458)	Three Days/Week	Composite	Influent & Effluent
Fecal Coliform Bacteria (#/100 mL)	200	400	Two Days/Week	Grab	Effluent
Ammonia, as N	1.5 (18)	2.25 (23)	Three Days/Week	Composite	Effluent
Total Phosphorus, as P	Report (Report)	Report (Report)	Three Days/Week	Composite	Effluent

(Effluent Limitations continued on the next page)