

B. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (JUNE - DECEMBER)  
CONTINUED

Parameter	Discharge Limitations mg/L unless otherwise specified	Monitoring Requirements		
		Measurement Frequency	Sample Type	Sample Location
Ortho-Phosphate (as P)	Report (Report)	One Day/Month	Composite	Effluent
Total Kjeldahl Nitrogen (TKN)	Report	One Day/Month	Composite	Effluent
Nitrate-Nitrite (as N)	Report	One Day/Month	Composite	Effluent
Chronic Whole Effluent Toxicity (WET) <sup>2</sup>	Report NOEC	Annually	Composite	Effluent
Long Term Biochemical Oxygen Demand <sup>3</sup>	Report	One/Five Years	Composite	Effluent
pH, Minimum – Maximum (Standard Unit)	6.0 – 8.5	Seven Days/Week	Grab	Effluent
Dissolved Oxygen, Daily Minimum June and September – December	7.0	Seven Days/Week	Grab	Effluent
July – August	6.0	Seven Days/Week	Grab	Effluent

<sup>2</sup>Refer to Part I.C.8., CHRONIC WHOLE EFFLUENT TOXICITY

<sup>3</sup>Refer to Part I.C.9., LONG TERM BIOCHEMICAL OXYGEN DEMAND