

9. LONG TERM BIOCHEMICAL OXYGEN DEMAND TESTING

The permittee shall perform a 120 day long term BOD test, once during the term of the permit. The test should be performed on an effluent sample collected during the critical period from June 1 through September 30. The results of this test should be provided to EPD prior to renewal of the permit.

10. WATERSHED PROTECTION PLAN

The permittee has developed a watershed protection plan and the plan has been approved by EPD. The watershed protection plan shall be enforceable through this permit.

Annual Report

Each June 30th the permittee is to submit the following to EPD:

- a. An annual certification statement documenting that the plan is being implemented as approved. The certification statement shall read as follows: "I certify, under penalty of law, that the watershed protection plan is being implemented. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."
- b. All watershed plan data collected during the previous year in an electronic format. This data shall be archived using a digital format such as a spreadsheet developed in coordination with EPD. All archived records, data, and information pertaining to the watershed protection plan shall be maintained permanently.
- c. A progress report that provides a summary of the BMPs that have been implemented and documented water quality improvements. The progress report shall also include any necessary changes to the Watershed Protection Plan.