

**DoD Component Summary  
Number of Installations and Drinking Water Systems Tested for  
Perfluorooctane Sulfonate (PFOS) Perfluorooctanoic Acid (PFOA)**

Summary of DoD Drinking Water Systems							
DoD Component	Number of Installations in US/Territories/Overseas <sup>1</sup>	Number of DoD Drinking Water Systems for DoD Installations		Number of DoD Drinking Water Systems Tested by Either DoD or the non-DoD Purveyor		Number of DoD Drinking Water Systems Tested Where PFOS/PFOA > EPA LHA <sup>3</sup>	
		DoD Purveyor	Non-DoD Purveyor	DoD Purveyor	Non-DoD Purveyor <sup>2</sup>	DoD Purveyor	Non-DoD Purveyor
<b>Army</b>	2,905	255	2,738	255	1,589	12	4
<b>Navy</b>	108	100	236	100	236	5	1
<b>USMC</b>	68	28	52	28	52	1	2
<b>Air Force</b>	177	140	134	140	134	6	5
<b>DLA</b>	8	1	7	1	7	0	0
<b>DoD Totals</b>	<b>3,266</b>	<b>524</b>	<b>3,167</b>	<b>524</b>	<b>2,018</b>	<b>24</b>	<b>12</b>

**Footnotes:**

1: Includes Guard and Reserve facilities.

2: Non-DoD purveyor tested most of these systems so far as required under the EPA's Unregulated Contaminant Monitoring Rule 3 or per request from DoD. For systems not tested, the DoD Components are assessing on a case-by-case basis to determine if the systems may be impacted and needs testing.

3: The EPA Lifetime Health Advisories (LHAs) for PFOS and PFOA are 70 parts per trillion (individually or combined).

The information included in the table above is current as of August 31, 2017.