

Defense Logistics Agency

Summary of DoD Testing of Groundwater Monitoring Wells and Actions Taken where Results were above the EPA LHA for PFOS/PFOA

Defense Logistics Agency Installations where DoD Sampled Groundwater Monitoring Wells and Actions Taken where Results were Above the EPA LHAs ¹										
DoD Component ²	Installation	State/Territory	On-base Groundwater Monitoring Wells			Off-base Groundwater Monitoring Wells			Actions Taken as of August 31, 2017 ³	Key Actions Planned for FY 2018 to Reduce PFOS/PFOA Below LHA
			Total Number Sampled	Number that Tested above the EPA LHAs ¹	Range of Results above EPA LHAs (ppt)	Total Number Sampled	Number that Tested above the EPA LHAs ¹	Range of Results above EPA LHAs (ppt)		
DLA Energy	DFSP Newington ⁴	New Hampshire	11	9	90-1270 ppt	0	N/A	N/A	N/A	Actions under development in coordination with regulators
DLA Energy	DFSP Verona ⁴	New York	9	5	86-1300 ppt	0	N/A	N/A	N/A	Actions under development in coordination with regulators
Footnotes:										
1: The EPA Lifetime Health Advisories (LHAs) for PFOS and PFOA are 70 parts per trillion (individually or combined).										
2: DLA Energy plans, programs, budgets, and executes investigation and cleanup of fuel releases through Defense Working Capital Fund.										
3: Examples of actions taken include but are not limited to: sampling and analysis, retesting, shutting down a well(s), providing alternative drinking water, adding an activated carbon filter to the well, and blending water systems.										
4: DLA Energy is working to close this site and return property to Air Force										