

11. The permittee must mitigate interference with existing legal uses caused in whole or in part by the permittee's withdrawals, consistent with a District-approved mitigation plan. As necessary to offset such interference, mitigation may include, but is not limited to, reducing pumpage, replacing the existing legal user's withdrawal equipment, relocating wells, changing withdrawal source, supplying water to existing legal user, or other means needed to mitigate the impacts.
12. The permittee must mitigate harm to existing off-site land uses caused by the permittee's withdrawals. When harm occurs, or is imminent, the permittee must modify withdrawal rates or mitigate the harm.
13. The permittee must mitigate harm to the natural resources caused by the permittee's withdrawals. When harm occurs or is imminent, the permittee must modify withdrawal rates or mitigate the harm.
14. If any condition of the permit is violated, the permittee shall be subject to enforcement action pursuant to chapter 373, F.S.
15. The permittee must notify the District in writing prior to implementing any changes in the water use that may alter the permit allocations. Such changes include, but are not limited to, change in irrigated acreage, crop type, irrigation system, water treatment method, or entry into one or more large water use agreements. In the event a proposed change will alter the allocation, permittee must first obtain a permit modification.
16. All correspondence sent to the District regarding this permit must include the permit number **(2-121-219095-6)**.
17. The District reserves the right to open this permit, following notice to the permittee, to include a permit condition prohibiting withdrawals for resource protection.
18. The permittee shall implement automated monitoring of groundwater withdrawals, at permittee's expense, upon commencement of withdrawals. Monthly reports shall include volume pumped by each well of inside diameter eight inches or greater at land surface and shall be delivered within the following month in an approved District format.
19. The permittee shall maintain all totalizing flow meters. In case of failure or breakdown of any meter, the District shall be notified in writing within five days of its discovery. A defective meter shall be repaired or replaced within 30 days of its discovery.