


**NARRATIVE**

ALL WASTEWATER TO THIS FACILITY IS PUMPED THROUGH THE INFLUENT PUMPING STATION AND RECEIVES TREATMENT IN A THREE CELL POND SYSTEM. THE CELLS ARE SEPARATED WITH CURTAIN BAFFLES AND THE FIRST TWO CELLS ARE AERATED. EFFLUENT FROM THE THIRD CELL IS CHLORINATED FOLLOWED BY DE-CHLORINATION PRIOR TO DISCHARGE TO CAT CREEK.



**COASTAL ENGINEERING CONSULTANTS**

COASTAL ENGINEERING CONSULTANTS, INC.  
 P. O. BOX 20306  
 ST. SIMONS ISLAND, GEORGIA 31522  
 PHONE: (912) 223-0647  
 EMAIL: johnh@cec-ga.com

THIS DRAWING IS AN INSTRUMENT OF SERVICE AND REMAINS THE PROPERTY OF COASTAL ENGINEERING CONSULTANTS, INC. THIS DRAWING MAY NOT BE REPRODUCED IN WHOLE OR IN PART WITHOUT THE WRITTEN PERMISSION OF COASTAL ENGINEERING CONSULTANTS, INC.

**GENERAL NOTES AND LEGEND**

- INFLUENT PUMPING STATION
- MECHANICAL AERATOR
- POND OUTLET STRUCTURE
- CHLORINE CONTACT TANK AND FLOW METERING
- DIRECTION OF FLOW

FILE NUMBER: 2017-001-EXHIBIT A	DATE: JANUARY 12, 2017
PROJECT NAME: <b>RAY CITY, GEORGIA WASTEWATER TREATMENT PLANT</b>	
APPLICATION FOR RENEWAL OF NPDES PERMIT GA0039365	
SHEET TITLE: <b>PROCESS FLOW SCHEMATIC</b> REF: FORM 2A-ITEM B.3	
SCALE: NONE	<b>EXHIBIT B</b>