

11. Sewer repairs near Sustella Avenue.

HISTORY: Utilities personnel responded to a report of a cave-in near a manhole off Sustella Avenue. Following their investigation and a subsequent evaluation of the sewer system, they determined that a section of the 30-inch concrete sanitary sewer main had collapsed. The collapse was a major source of stormwater inflow and risked causing sewer backups and overflows. Staff quickly stationed a bypass pump at the location and contacted a contractor to make the repair. Subsequent research showed that the entire 325 linear feet(LF) of main was deteriorated and in danger of further collapse. Additionally, this section of the system was previously identified for replacement due to its age and recent failures along with other sections.

Status: Completed

12. Repairs to the Sugar Creek Aerial Sewer Main.

History: Utilities crew responded to a report of a leaking sewer main near the 1700 block of West Gordon Street. Following their investigation of the call and a subsequent evaluation of the sewer lines in the area, personnel determined that a 16-inch aerial sewer main section had rusted through, causing a small leak. The Utilities crew quickly repaired the pipe and stopped the leak. Additional main inspection showed evidence of advanced corrosion and deterioration along multiple exposed pipe sections. Staff determined; to prevent further leaks and major pipe failure, the best course of action was to replace the main as soon as possible.

Status: Completed