

13. Sewer main repairs on North Oak Street near One- Mile Branch.

HISTORY: Utilities Department was informed of a developing sinkhole adjacent to an existing Sanitary Manhole on North Oak Street near the Valdosta State University (VSU) Campus. After further inspection by Utilities Central Lines crews, it was determined that the existing 24" Reinforced Concrete Pipe (RCP) Sanitary Sewer Main had failed/ collapsed and had caused the sinkhole. Utility contractors were contacted to help making the repairs.

Status: Completed

14. Installation of a new 24" sewer main across the railroad right-of-way at highway 84 East.

History: The City's existing 20"ductile iron sanitary sewer line collapsed due to advanced deterioration. The city engaged Underground Contractors to design and repair the existing sewer main. Approve the Resolution authorizing the adoption and execution of the Facility Encroachment Agreement for the necessary sewer main repairs to be completed at this railroad right-of-way crossing.

Status: Completed