

15. Repairs for a sanitary sewer main collapse at Highway 84 and Blanchard Street.

HISTORY: There was a significant reduction in flow was detected at the Mud Creek Water Pollution Control Plant (WPCP). The Utilities Department Staff immediately commenced an investigation to identify the location of the system loss. A collapsed 21" diameter sanitary sewer trunk line was located near the intersection of Highway 84 and Blanchard Street on the southside of the CSX railroad. Utilities Department Staff selected Underground Contractors to establish a temporary system bypass and to perform any repair work necessary to repair the deteriorated lines.

Status: Completed

16. Repairs to Sanitary Sewer Line near Knights Creek off Highway 84 and Blanchard Street.

HISTORY: There was a significant reduction in flow was detected at the Mud Creek Water Pollution Control Plant (WPCP). The Utilities Department Staff immediately commenced an investigation to identify the location of the system loss. A collapsed 21" diameter sanitary sewer trunk line was located near the intersection of Hwy. 84 and Blanchard Street on the southside of the CSX railroad. The Utilities Department Staff selected Underground Contractors to perform any repair work necessary to repair the deteriorated lines.

Status: Completed