

19. Sewer repairs at Knights Creek near the intersection of U. S. Highway 84 and Blanchard Street.

HISTORY: There was a significant reduction in flow was detected at the Mud Creek Water Pollution Control Plant. Utilities Department Staff immediately commenced an investigation to identify the location of the system loss. A collapsed 21" diameter sanitary sewer trunkline was located near the intersection of Hwy. 84 and Blanchard Street on the southside of the CSX railroad.

Status: Completed.

20. Installation of a small diameter Sanitary Force Main on Trotters Way.

HISTORY: This cul-de-sac in northwest Valdosta does not have sewer service provided to eight residential lots. These properties are served by City water and individual, private septic treatment systems. Overtime, on-site septic systems deteriorate and fail. This is the case for one of these residences. The city is proposing the most cost-effective means of serving these residential lots with City sewer.

Status: Completed