

administratively extended until this order is executed, then a new permit shall be issued. The Facility is located at 2221 Buckman Street, Jacksonville, in Duval County, Florida (Property). Respondent owns the Property on which the Facility is located.

4. The Department finds that the following violation(s) occurred:
- a) Chronic Whole Effluent Toxicity (WET) failures have been recurring since the issuance of Permit in June 2019. The Permit was issued in conjunction with Administrative Order (AO) 200, for chronic toxicity issues. The permittee was to comply with the toxicity requirements by December 2023. The permittee failed to meet these Administrative Order WET requirements. The WET violations are noted in the table below:

Table 1: Chronic Whole Effluent Toxicity - IC25

<u>Date</u>	<u>Monitoring Location</u>	<u>Description</u>	<u>Result</u>	<u>Limits</u>	<u>Units</u>	<u>Statistical Base</u>
06/30/2025	EFD-1	IC25 Statre 7day Chr Mysid Bahia	54.87	100	percent	Minimum
06/30/2024	EFD-1	IC25 Statre 7day Chr Mysid Bahia	38.97	100	percent	Minimum
06/30/2023	EFD-1	IC25 Statre 7day Chr Mysid Bahia	33.93	100	percent	Minimum
04/30/2022	EFD-1	IC25 Statre 7day Chr Mysid Bahia	29.77	100	percent	Minimum
10/31/2021	EFD-1	IC25 Statre 7day Chr Mysid Bahia	15.3	100	percent	Minimum
01/31/2021	EFD-1	IC25 Statre 7day Chr Mysid Bahia	57.8	100	percent	Minimum
05/31/2020	EFD-1	IC25 Statre 7day Chr Mysid Bahia	65.41	100	percent	Minimum