

02/29/2020	EFD-1	IC25 Statre 7day Chr Mysid Bahia	38.69	100	percent	Minimum
10/31/2022	EFD-1	IC25 Statre 7day Chr Mendoza	91.6	100	percent	Minimum

b) Permit Condition 1.A.1 "Effluent Limitations and Monitoring Requirements, Surface Water Discharges," sets effluent limitations for Aldrin and Total Cyanide. These limits were not met as shown in the Table below:

Table 2: Aldrin and Total Cyanide

<u>Date</u>	<u>Monitoring Location</u>	<u>Description</u>	<u>Result</u>	<u>Limit</u>	<u>Units</u>	<u>Statistical Base</u>
06/30/2024	EFD-1	Aldrin	0.01165	1.4E-4	µg/L	Annual Average
03/31/2024	EFD-1	Aldrin	0.0116875	1.4E-4	µg/L	Annual Average
12/31/2023	EFD-1	Aldrin	0.0059	1.4E-4	µg/L	Annual Average
09/30/2023	EFD-1	Aldrin	0.0058625	1.4E-4	µg/L	Annual Average
03/31/2022	EFD-1	Aldrin	0.0078125	1.4E-4	µg/L	Annual Average
12/31/2021	EFD-1	Aldrin	0.0078125	1.4E-4	µg/L	Annual Average
09/30/2021	EFD-1	Aldrin	0.0092625	1.4E-4	µg/L	Annual Average
06/30/2021	EFD-1	Aldrin	0.009275	1.4E-4	µg/L	Annual Average
03/31/2021	EFD-1	Aldrin	0.00375	1.4E-4	µg/L	Annual Average
12/31/2020	EFD-1	Aldrin	0.004025	1.4E-4	µg/L	Annual Average
04/30/2025	EFD-1	Cyanide, Total (as CN)	5.0	1.0	ug/L	Maximum