

**Table 5 - WET Interim Limits**

<u>Parameter</u>	<u>Units</u>	<u>Max/Min</u>	<u>Limit</u>	<u>Statistical Basis</u>	<u>Frequency of Analysis</u>	<u>Monitoring Site</u>	<u>Sample Type</u>
Chronic Whole Effluent Toxicity, 7-Day IC25 ( <i>Americamysis bahia</i> )	percent	Min	Report	Single Sample	Bimonthly	EFD-1	24-hr FPC
Chronic Whole Effluent Toxicity, 7-Day IC25 ( <i>Menidia beryllina</i> )	percent	Min	Report	Single Sample	Bimonthly	EFD-1	24-hr FPC

- a) Tests conducted pursuant to this monitoring program shall conform to Rule 62-4.246, Rule 62-160, and Rule 62-600, F.A.C., and 40 Code of Federal Regulations 136, as appropriate.
- b) Analyses shall be reported electronically using the Department's Electronic Discharge Monitoring Reports (DMR) System. Completed DMRs must be submitted by the 28th of the month following the month of operation.
- c) These monitoring requirements do not act as State of Florida Department of Environmental Protection Wastewater Permit effluent limitations, nor do they authorize or otherwise justify violation of the Florida Air and Water Pollution Control Act (Act), Part I, Chapter 403, F.S., during the pendency of this Order.

8. Every quarter after the effective date of this Order and continuing until all corrective actions have been completed, Respondent shall submit to the Department a written report containing information about the status and progress of projects being completed under this Order, information about compliance or noncompliance with the applicable requirements