

CONSTRUCTION SCHEDULE AND TECHNIQUES:

4. The submitted response noted that no offsite discharges are anticipated in the dewatering process and stated that this is located on Sheet C3.0. Please clarify the location of this note further as I was not able to locate it on the submitted plans. [Rule 62-330.301(1)(i), F.A.C.]

Response: Sheet C3.0 includes the following note at least 3 places. The project states that there will be no dewatering, therefore the note does not include a dewatering reference.



DRAINAGE INFORMATION:

5. It appears that storage modelling is used to demonstrate there will be no adverse offsite impacts due to the proposed encroachment. Please provide the following items to provide reasonable assurance the encroachment is accurately modelled, and no adverse offsite impacts will occur. [Section 3.3, A.H.V.II]

- a. Delineate the extent of the proposed encroachment and any proposed compensation on the submitted plans. Please label each of the impacts as they are labelled in the submitted calculations.

Response: The requested information has been added to the plans

- b. If the regional model is used to determine the utilized floodplain elevations, no action is needed on this item. If it is not used, please provide clarification on how these elevations were determined.

Response: The regional model was utilized to determine the utilized floodplain elevations.

The following comments, although not required by District rule, are provided for your consideration and information:

6. Please note that this will be your only request for clarification and once your response is received your application will be considered complete. Please ensure that you respond to all questions completely.

Response: Noted.

7. Please be aware that applications not deemed complete by December 28, 2025 are subject to the water quality treatment performance criteria established in Senate Bill 7040, ratified on June 28,