

“Closed loop system: A system that constantly reuses and recycles an initial load of water within its operation, significantly reducing the draw on external water sources and minimizing wastewater discharge. A closed loop system shall not use evaporative cooling, and may consist of methods including, but not limited to, air-cooled (dry) cooling, rear-door heat exchanger cooling, hybrid dry economizer cooling, direct-to-chip cooling, or immersion cooling.”¹⁹

The GWC thanks the Southern Georgia Regional Commission for the opportunity to comment on this DRI. If you have any questions, please contact Chris Manganiello:
cmanganiello@chattahoochee.org

Sincerely,

The Georgia Water Coalition

¹⁹ AN ORDINANCE TO AMEND CHAPTER 27, ARTICLE 4 AND ARTICLE 9 OF THE CODE OF DEKALB COUNTY, GEORGIA, AS REVISED 1988 TO ADD REGULATIONS FOR DATA CENTERS IN DEKALB COUNTY, <https://engagedekalb.dekalbcountyga.gov/data-center-text-amendment>