

- 17. The permittee shall use the lowest quality water source, such as reclaimed water, surface/storm water, or alternative water supply, to supply the needs of the project when deemed feasible pursuant to District rules and applicable state law.
- 18. The permittee must ensure that all service connections are metered.
- 19. The permittee shall continue to implement the use of reclaimed water, to offset groundwater withdrawals, to the maximum extent possible, unless the permittee demonstrates that implementation is not technically, economically, and environmentally feasible. In implementing the use of reclaimed water to meet irrigation demands, the permittee must consider all feasible measures.
- 20. The permittee must implement the Water Conservation Plan submitted to the District on October 30, 2025, in accordance with the schedule contained therein.
- 21. All submittals made to demonstrate compliance with this permit must include CUP number 11339-8 labeled on the submittal. Submittals should be made online at www.sjrwmd.com/permitting whenever possible.
- 22. This permit will expire on June 9, 2056.
- 23. Maximum annual groundwater withdrawals from the Upper Floridan aquifer for public supply use must not exceed 12,626.00 million gallons (34.6 mgd, annual average) pursuant to conditions of this permit.
- 24. Total withdrawal from the Upper Floridan aquifer wells listed below, must be recorded continuously, totaled monthly, and reported to the District at least every six months for the duration of this permit using Water Use Pumpage Report Form (EN-50). The meter reading or quantity withdrawn must be reported in gallons.

Station ID	Station Name
3387	A1
3388	B2
3389	C3
3390	D4
3391	E5
3392	F6
3393	G7
3394	H8
3395	I9
3397	K11
22424	L12

Attachment: GRU TSR Final (Murphree WTP - GRU, 11339-8)