

22425	M13
22426	N14
22427	O15
39525	P16
39526	Q17

Reporting is required, even if there is no use. The reporting dates each year will be as follows:

<u>Reporting Period</u>	<u>Report Due Date</u>
January - June	July 31
July - December	January 31

- 25. Prior to use, all existing and proposed wells must be equipped with totalizing flow meters. All flow meters must measure within +/- 5% of the actual flow, be verifiable and be installed according to the manufacturer's specifications.
- 26. The permittee must have all flow meters checked for accuracy at least once every 10 years, specifically before December 15, 2033, and recalibrated if the difference between the actual flow and the meter reading is greater than 5%. Flow Meter Accuracy Report Form (EN-51) must be submitted to the District within 10 days of the inspection/calibration.
- 27. The permittee must maintain all flowmeters. In case of failure or breakdown of any meter, the District must be notified in writing within 5 days of its discovery. A defective meter must be repaired or replaced within 30 days of its discovery.
- 28. By March 31 each year, the permittee shall submit an Annual Aquifer Recharge and Water Level Monitoring Report the District. The report must include the volume of water (in total gallons) associated with each of the following recharge projects:
 - a. Kanapaha Recharge Wells
 - b. MSWRF discharge to Sweetwater Branch
 - c. Kanapaha Water Reclamation Facility Wetlands
 - d. Chapmans Trails Pond
 - e. Kanapaha Middle School Wetland
 - f. Kanapaha Botanical Gardens
 - g. UF Recharge Well

Attachment: GRU TSR Final (Murphree WTP - GRU, 11339-8)