

14642	PL-2	Ponte Vedra South
24083	PL-3	Ponte Vedra South
24084	PL-4	Ponte Vedra South
34049	ML-1	Ponte Vedra South
14822	ML-2	Ponte Vedra South
14640	SG-1	Ponte Vedra South
15110	SG-2	Ponte Vedra South
14780	TR-42	Tillman Ridge Wellfield
484406	TR-43R	Tillman Ridge Wellfield
34242	TR-45	Tillman Ridge Wellfield
34243	TR-46	Tillman Ridge Wellfield
36031	TR-47	Tillman Ridge Wellfield
38399	TR-48	Tillman Ridge Wellfield
38400	TR-49	Tillman Ridge Wellfield
404712	TR-50	Tillman Ridge Wellfield
404714	TR-51	Tillman Ridge Wellfield
567064	W-1	West Wellfield
567065	W-2	West Wellfield
567066	W-3	West Wellfield
567067	W-4	West Wellfield
567068	W-5	West Wellfield
567069	W-6	West Wellfield
567070	W-7	West Wellfield
567071	W-8	West Wellfield
567072	W-9	West Wellfield
567073	W-10	West Wellfield

25. The permittee must have all flow meters checked for accuracy at least once every 10 years and recalibrated if the difference between the actual flow and the meter reading is greater than 5%. Flow Meter Accuracy Report Form (EN-51) must be submitted to the District within 30 days of the inspection/calibration.
26. The permittee must maintain all flowmeters and alternative methods for measuring flow. In case of failure or breakdown of any meter, the District must be notified in writing within 5 days of its discovery. A defective meter must be repaired or replaced within 30 days of its discovery.
27. The permittee must have in place a process for reporting, recording and documenting unmetered water uses including, but not limited to, main breaks, sewer cleaning, and water quality flushing.
28. The permittee must ensure that all service connections are metered.